

TÜV Rheinland LGA Products GmbH • 51105 Cologne • Germany

Aerzener Maschinenfabrik GmbH
Reherweg 28
31855 Aerzen

Your correspondence
Dr. Norbert Horlemann

Order-No.:1072622_GM

Phone +49 (0)221-806-1896
Fax +49 (0)221-806-1461
Mail horlema@de.tuv.com

Customer Service Center
for Products
Phone +49 911 655-5225

Mail service@de.tuv.com

Cologne, 11 October 2011

Type test certificate

Dear Sirs,

We have measured the total oil content (aerosols, liquids and vapours) in the outlet air stream of an oil-free positive displacement blower with 3-lobe rotors, type GM. The measurements were done in accordance with the following guidelines and standards:

ISO 8573-1: 2010 Part 1: Contaminants and purity classes

ISO 8573-2: 2007 Part 2: Test methods for aerosol oil content, method B2 (Partial-flow sampling)

ISO 8573-5: 2001 Part 5: Test methods for oil vapor and organic solvent content

This being a type test, covering the entire range of oil-free positive displacement blower with 3-lobe rotors, type GM between GM 3 S and GM 1200 L and a power range between 0.5 and 1200 kW a model was randomly selected for the tests. The tests were carried out at the outlet of the positive displacement blower without any oil removal devices in between the compressor and the measurement point. The conditions of the test were:

Temperature at the measurement point: ambient temperature (ca. 25 °C)

Pressure at the outlet of the positive displacement blower: ca. 1.0 bar (e)

TÜV Rheinland
LGA Products GmbH

Am Grauen Stein 29
51105 Cologne
Germany

Headquarter

TÜV Rheinland
LGA Products GmbH

Tillystraße 2
90431 Nuremberg
Germany

Phone +49 911 655 5225
Fax +49 911 655 5226
service@de.tuv.com
www.tuv.com/safety


Board of Management

Dipl.-Ing.
Jörg Mähler, Spokesman


Dipl.-Kfm.
Dr. Jörg Schiösser

Nuremberg HRB 26013
VAT No.: DE811835490

Principle diagram for full flow measurement of Aerosols and liquids as per ISO 8573 Part 2, method B2



Principle diagram for measurement of oil vapour and organic solvent content as per ISO 8573 Part 5



Legend :

- P : Pressure indicator
- T : Temperature indicator
- M : Measurement point with membrane
- F : Flow meter
- S : Silencer
- C : Measurement point for oil vapour

It is to certify that at the test conditions, no oil (<math><0.01 \text{ mg/m}^3</math>) deriving from the compressor (including all hydrocarbons C6 and above) could be detected in the compressed air stream. On the basis of this test, we can certify the results to be applicable for all oil-free positive displacement blowers with 3-lobe rotors, type GM between GM 3 S and GM 1200 L and a power range between 0.5 and 1200 kW.

It is to certify that the quality of air from the above blowers qualifies to be in the category 'Class 0' in terms of total oil content, as defined in the standard ISO 8573-1 : 2010 Part 1.

A detailed report with all conditions of the tests and results is available.

Best Regards

i. V. 
 Dr. rer. nat. Walter Dormagen

i. A. 
 Dr. rer. nat. Norbert Horlemann